



APPROVALS®

## Certificate of Approval

**Certificate No.:** SAA-152275-EA

**Certificate Holder:** Yueqing Langir Electric Co., Ltd.  
4F, No.188 Liuqing North Road, Liushi,  
Wenzhou,  
P.R. China

**Class Description:** Miniature Overcurrent Circuit-Breaker  
**Product Description:** DC Circuit Breaker 1P, 2P, 3P, 4P  
Utilisation Category A

**Brand Name:** langir

**Model No.:** JB

**Markings:** 250Vdc (1P)  
500Vdc (2P)  
750Vdc (3P)  
1000Vdc (4P)  
In= 1A, 2A, 3A, 4A, 6A, 10A, 16A, 20A, 25A,  
32A, 40A, 50A, 63A

$I_{cu}=I_{cs}= 10kA$

Instantaneous tripping curve C-type, D-type, K-type

**Standard:** AS 60947.2:2005

AS 60947.1:2004

**Conditions:** Nil

**Approval Mark:** SAA-152275-EA or RCM

**Date First Registered:** 14 December 2015

**Date of Expiry:** 14 December 2020

For and on Behalf of  
SAA Approvals Pty Ltd

SAA Approvals Pty Ltd as accredited by JAS-ANZ under ISO/IEC 17065 certifies in accordance with the SAA Approvals Electrical Product Safety Certification Scheme that the product nominated in this certificate complies with standard/s listed.

When using the RCM the requirements of all relevant parts of AS/NZS 4417 applicable to the article must be fulfilled.

For SAA Contact Details and to verify this Certificate go to:  
[www.saaapprovals.com.au](http://www.saaapprovals.com.au)

JAS-ANZ



[www.jas-anz.org/register](http://www.jas-anz.org/register)



Issued: 14-12-15 152275/1